



OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	260036660
Drinking-Water System Name:	Ryerson Camp
Drinking-Water System Owner:	United Church Outdoor Ministries - Hamilton Conference
Drinking-Water System Category:	Small Non-Municipal Non-Residential
Period being reported:	01 April 2009 - 31 March 2010

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection. <div style="border: 1px solid black; padding: 5px; width: 100%;">www.ryersoncamp.com</div> </p>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; padding: 5px; width: 100px; text-align: center;">1</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [X] No []</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; padding: 5px; width: 100px; display: inline-block;"></div></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System	Name Drinking Water System Number
N/Ap	N/Ap

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [X] No []



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

Drilled Well (~ 300 ft), pumping to Reservoir where water is treated with Chlorine, and then pumped to the Water System

List all water treatment chemicals used over this reporting period

Chlorine

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Beyond System Maintenance no Installations or Major Repairs were conducted

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/Ap	N/Ap	N/Ap	N/Ap	N/Ap	N/Ap



Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	4	0-0	0-84	0	0
Treated	2	0-0	0-0	6	0-
Distribution	7	0-0	0-0	7	0-20

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	N/Ap	N/Ap
Chlorine	105	0.15-0.6
Fluoride (If the DWS provides fluoridation)	N/Ap	N/Ap

NOTE: For continuous monitors use 8760 as the number of samples.

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/Ap	N/Ap	N/Ap	N/Ap	N/Ap

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	08Jun04	<0.0005	mg/L	
Arsenic	08Jun04	<0.002	mg/L	
Barium	08Jun04	0.120	mg/L	
Boron	08Jun04	0.865	mg/L	
Cadmium	08Jun04	<0.0001	mg/L	
Chromium	08Jun04	<0.005	mg/L	
Lead	08Jun04	<0.0005	mg/L	
Mercury	08Jun04	<0.0001	mg/L	
Selenium	08Jun04	<0.002	mg/L	
Sodium	08Jun04	87.3	mg/L	
Uranium	08Jun04	<0.0001	mg/L	
Fluoride	08Jun04	2.0	mg/L	1.5/2.4

Nitrite	30Jun08	<0.005	mg/L	
Nitrate	30Jun08	<0.013	mg/L	

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	08Jun04	N.D.	mg/L	
Aldicarb	08Jun04	N.D.	mg/L	
Aldrin + Dieldrin	08Jun04	N.D.	mg/L	
Atrazine + N-dealkylated metabolites	08Jun04	N.D.	mg/L	
Azinphos-methyl	08Jun04	N.D.	mg/L	
Bendiocarb	08Jun04	N.D.	mg/L	
Benzene	08Jun04	N.D.	mg/L	
Benzo(a)pyrene	08Jun04	N.D.	mg/L	
Bromoxynil	08Jun04	N.D.	mg/L	
Carbaryl	08Jun04	N.D.	mg/L	
Carbofuran	08Jun04	N.D.	mg/L	
Carbon Tetrachloride	08Jun04	N.D.	mg/L	
Chlordane (Total)	08Jun04	N.D.	mg/L	
Chlorpyrifos	08Jun04	N.D.	mg/L	
Cyanazine	08Jun04	N.D.	mg/L	
Diazinon	08Jun04	N.D.	mg/L	
Dicamba	08Jun04	N.D.	mg/L	
1,2-Dichlorobenzene	08Jun04	N.D.	mg/L	
1,4-Dichlorobenzene	08Jun04	N.D.	mg/L	
Dichlorodiphenyltrichloroethane (DDT) + metabolites	08Jun04	N.D.	mg/L	
1,2-Dichloroethane	08Jun04	N.D.	mg/L	
1,1-Dichloroethylene (vinylidene chloride)	08Jun04	N.D.	mg/L	
Dichloromethane	08Jun04	N.D.	mg/L	
2-4 Dichlorophenol	08Jun04	N.D.	mg/L	
2,4-Dichlorophenoxy acetic acid (2,4-D)	08Jun04	N.D.	mg/L	
Diclofop-methyl	08Jun04	N.D.	mg/L	
Dimethoate	08Jun04	N.D.	mg/L	
Dinoseb	08Jun04	N.D.	mg/L	
Diquat	08Jun04	N.D.	mg/L	
Diuron	08Jun04	N.D.	mg/L	
Glyphosate	08Jun04	N.D.	mg/L	
Heptachlor + Heptachlor Epoxide	08Jun04	N.D.	mg/L	
Lindane (Total)	08Jun04	N.D.	mg/L	
Malathion	08Jun04	N.D.	mg/L	
Methoxychlor	08Jun04	N.D.	mg/L	
Metolachlor	08Jun04	N.D.	mg/L	



Metribuzin	08Jun04	N.D.	mg/L	
Monochlorobenzene	08Jun04	N.D.	mg/L	
Paraquat	08Jun04	N.D.	mg/L	
Parathion	08Jun04	N.D.	mg/L	
Pentachlorophenol	08Jun04	N.D.	mg/L	
Phorate	08Jun04	N.D.	mg/L	
Picloram	08Jun04	N.D.	mg/L	
Polychlorinated Biphenyls(PCB)	08Jun04	N.D.	mg/L	
Prometryne	08Jun04	N.D.	mg/L	
Simazine	08Jun04	N.D.	mg/L	
THM (NOTE: show latest annual average)	08Jun04	N.D.	mg/L	
Temephos	08Jun04	N.D.	mg/L	
Terbufos	08Jun04	N.D.	mg/L	
Tetrachloroethylene	08Jun04	N.D.	mg/L	
2,3,4,6-Tetrachlorophenol	08Jun04	N.D.	mg/L	
Triallate	08Jun04	N.D.	mg/L	
Trichloroethylene	08Jun04	N.D.	mg/L	
2,4,6-Trichlorophenol	08Jun04	N.D.	mg/L	
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	08Jun04	N.D.	mg/L	
Trifluralin	08Jun04	N.D.	mg/L	
Vinyl Chloride	08Jun04	N.D.	mg/L	

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)